

Attestation

BREEAM[®]

On the 10th of April, Eurofins Product Testing A/S received a sample of a panel with the product name:

OKOUPLEX

supplied by

JOUBERT LES ELIOTS

The sample was supplied as being representative of the manufactured product, and it has been tested as in accordance with the relevant EN 16516, ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11 testing standards (See test report no. 392-2022-00165705_Q_FR).

The test results of the tested sample indicate that the product qualifies for the below mentioned BREEAM specifications on VOC emissions by complying with:

- **BREEAM[®] International: Compliance with Exemplary criteria on VOC emission** of BREEAM International: New Construction 2021, Technical Manual – SD250: Hea 02 Indoor Air Quality (version 6.0. of December 2021).
- **BREEAM[®] UK: Compliance with Exemplary criteria on VOC emission** of BREEAM UK: New Construction 2018, Technical Manual: Hea 02 Indoor Air Quality (version SD5078 issue 3.0 of July 2019).
- **BREEAM[®] NL: Compliance with Exemplary criteria on VOC emission** of BREEAM NL: Nieuwbouw 2020, Technical Manual: Hea 02 Interne Luchtkwaliteit (Version 1.0 of June 2020).
- **BREEAM[®] SE: Compliance with Exemplary criteria on VOC emission** of BREEAM SE: New Construction 2021, Technical Manual: Hea 02 Indoor Air Quality (version 6.0. of January 2023).
- **BREEAM[®] NOR: Compliance with Exemplary criteria on VOC emission** of BREEAM NOR: New Construction 2022, Technical Manual - SD5076NOR, Hea 02 Indoor Air Quality (version 6.0 of February 2022).

15 March 2023



Rasmus Verdier
Analytical Service Manager